



Certificate number: 2510739 (1)

Issued 16/10/2025

Expires 16/10/2030

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Dolphin Solutions Limited.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:
Dolphin Solutions Limited
Southpoint
Compass Park
East Sussex
TN32 5BS
United Kingdom



KUKreg4

Product Certificate

Appendix to Certificate number: 2510739

The following products belong to this certificate

<p>PRODUCT DESCRIPTION Range of wall mounted stainless steel infra-red actuated taps. ATS3 – Without Production Surveillance.</p>
<p>MODEL(S) DS111 DOLPHIN INFORM SLIMLINE 90° BENT SPOUT WALL TAP – THRU PANEL DS112 DOLPHIN INFORM SLIMLINE 90° BENT SPOUT WALL TAP – WALL PLATE DS113 DOLPHIN INFORM SLIMLINE 55° BENT SPOUT WALL TAP – THRU PANEL DS114 DOLPHIN INFORM SLIMLINE 55° BENT SPOUT WALL TAP – WALL PLATE</p>
<p>SIZE: ½" BSP(M).</p>
<p>SCOPE: Manufacturer recommended maximum working pressure 6 Bar & maximum operating temperature 65°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 65°C.</p>
<p>MARKING Dolphin logo on spout.</p>
<p>MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.</p>
<p>BACKFLOW PROTECTION NOTES Consideration must be made on installation to the airgap arrangement.</p>
<p>ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.</p>

Extra Notes